

Attersee Stadt Osnabrück

Untersuchungsergebnisse (Badesaison 15.05. - 15.09.2022)

Datum	E. coli	Enterokokken	Sichttiefe	Wassertemp.	Lufttemp.	Bemerkungen
03.05.2022	< 15 /100ml	< 15 /100ml	1-2 m	15,0 °C	7,0 °C	-
17.05.2022	< 15 /100ml	15 /100ml	1-2 m	20,7 °C	21 °C	-
01.06.2022	< 15 /100ml	< 15 /100ml	1-2 m	18,0 °C	13,9 °C	-
14.06.2022	< 15 /100ml	< 15 /100ml	1-2 m	21,1 °C	15,5 °C	-
28.06.2022	< 15 /100ml	< 15 /100ml	1-2 m	22,7 °C	21,0 °C	-
12.07.2022	< 15 /100ml	375 /100ml	1-2 m	n.b. °C	21,0 °C	-
26.07.2022	15 /100ml	61 /100ml	1-2 m	20,0 °C	19,0 °C	-
09.08.2022	15 /100ml	430 /100ml	1-2 m	23,0 °C	24,0 °C	-
23.08.2022	15 /100ml	15 /100ml	1-2 m	24,0 °C	31,0 °C	-
	/100ml	/100ml	m	°C	°C	

Richtwerte:

Escherichia coli (EC): 100/100ml

Enterokokken (IE): 100/100ml

Grenzwerte:

Escherichia coli (EC): 1800/100ml

Enterokokken (IE): 700/100ml